



ELEVATION - ECCENTRIC

General Notes:

1. All dimensions are in inches unless otherwise specified.
2. Only eccentric cone sections shall be used.
3. Type 1 frames and closed lids shall be heavy duty with indented top solid lid and stamped with the words "STORM" and "CARPENTERSVILLE", Neenah R-1713 or approved equal.
4. Adjustment: Three adjustment rings totaling 8" in height may be used. No more than two (2) of those rings may be precast concrete. The top ring in paved areas with crown adjustments shall be rubber.
5. When adjusting rings are required on structures, provide ADCCO WT-64 butyl sealant (or approved equal) between the adjusting rings and the structure.
6. Butyl rubber joint sealant by Ez-Stik (or approved equal) shall be applied on barrel section joints.
7. Structure shall be placed on a minimum 6" granular CA-6 bed.

Storm Manhole Type - A

STM-4 121107